



**WATERITE TECHNOLOGIES, INC.**  
1-885 Keewatin Street  
Winnipeg, Manitoba  
Canada R2X 2S7  
PHONE (204) 786-1604  
FAX (204) 783-1599  
Email: [waterite@waterite.com](mailto:waterite@waterite.com)  
Website: [www.waterite.com](http://www.waterite.com)

**WATERITE TECHNOLOGIES, INC.  
PRODUCT SPECIFICATION SHEET  
RO-MEM-005**

**BLACK MAX RO ELEMENTS TEMPERATURE  
CORRECTION FACTOR CHART**

Divide rated output by correction factor corresponding to the observed feed water temperature.

TEMPERATURE		CORRECTION FACTOR
°C	°F	
5	41.0	2.58
6	42.8	2.38
7	44.6	2.22
8	46.4	2.11
9	48.2	2.00
10	50.0	1.89
11	51.8	1.78
12	53.6	1.68
13	55.4	1.61
14	57.2	1.54
15	59.0	1.47
16	60.8	1.39
17	62.6	1.34
18	64.4	1.29
19	66.2	1.24
20	68.0	1.19
21	69.8	1.15
22	71.6	1.11
23	73.4	1.08
24	75.2	1.04
25	77.0	1.00
26	78.8	0.97
27	80.6	0.94
28	82.4	0.91
29	84.2	0.88
30	86.0	0.85



**SPEC RO-MEM-005**  
*May, 2002*